

TIMEsaver Maintenance

TIMEsaver Plumbing are essentially maintenance free.

Ballvalves should be checked as normal.

Copper Cylinders require limited maintenance.

If water quality dictates the cylinder can be drained to remove any sludge – ensure an adequate open vent is available.

It may be appropriate to ensure that all gauges and thermostats are checked as often as is felt required.

Ensure that the Coil Working Pressure does not exceed the maximum it is designed for.

Ensure that any Primary side inhibitors are at the correct level.

Ensure annually that all fittings are watertight.

Where Pumps are fitted, refer to the pump instructions for any maintenance requirements.